

NEWSFLASH



Date: August 31, 2006
To: All Refined Fuel Distributors, OEMs, and End Users
From: Curtis Fennell, Marketing Communications Manager
Topic: **Suitability of magnetic drive cover and dual-stage valve for cast iron meters**



Recently there have been a number of customer inquiries regarding the use of the new magnetic drive cover and two-stage valve with existing nodular (ductile) iron meters.

The magnetic drive cover will work with 2" nodular iron meters (style "N") for both petroleum and LPG, but only in conjunction with an E4000 Electronic Register. The magnetic drive cover is not designed for use with a mechanical register. The existing cover bolts can be reused for installation of the new cover.

The dual-stage LPG valve is not suitable for installation on an iron meter because of a difference in flange configuration.

Should you have any questions, please do not hesitate to call 1-800-833-3357 or e-mail flowmeas@greenwood.actaris.com.

NF#RF06-08W

